APPENDIX 1. NOTIFICATION TEMPLATE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Por favor hable con alguien que lo pueda tradúcir.

DRINKING WATER WARNING

Pleasant View West School water has high levels of nitrate DO NOT GIVE THE WATER TO INFANTS UNDER 6 MONTHS OLD OR PREGNANT WOMEN OR USE IT TO MAKE INFANT FORMULA

Water sample results received 2-21-23 [insert date] showed nitrate levels of __/0.7 [insert level and units]. This is above the nitrate standard, or maximum contaminant level (MCL),

of 10 milligrams per liter. Nitrate in drinking wasix months old.	vater is a serious health concern for infants less than
[insert level and units]. This is below the nitrate 10 milligrams per liter. Although the nitrate levels in the world in t	w the MCL. [insert date] showed nitrate levels of te standard, or maximum contaminant level (MCL), of vels during the most recent monitoring period showed ater tend to fluctuate and it is possible that the nitrate pling events. Public notification will continue until the

What should I do?

- DO NOT GIVE THE WATER TO INFANTS. Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. Symptoms in infants can develop rapidly, with health deteriorating over a period of days. If symptoms occur, seek medical attention immediately.
- PREGNANT WOMEN SHOULD NOT CONSUME THE WATER. High nitrate levels may also affect the oxygen-carrying ability of the blood of pregnant women.
- Water, juice, and formula for children under six months of age should not be prepared with tap water. Bottled water or other water low in nitrates should be used for infants until further notice.
- DO NOT BOIL THE WATER. Boiling, freezing, filtering, or letting water stand does not reduce the nitrate level. Excessive boiling can make the nitrates more concentrated, because nitrates remain behind when the water evaporates.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Nitrate in drinking water can come from natural, industrial, or agricultural sources (including septic systems, storm water run-off, and fertilizers). Levels of nitrate in drinking water can vary throughout the year. We will let you know if the amount of nitrate is again below the limit.

Describe corrective act to Joseph New out to We anticipate resolving	OFR Drinking	fountains x	yith filter	system Ins	d for fundamental	dinj foontains
For more information, p	lease contact:					
[PN Contact Name] [Phone Number] or [Mailing Address]	MARK 605A 559-784674 14004 ROAD		uille, CA. 9325	7		

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees
 of businesses located on the property.

This notice is being sent to you by Pleasant View West School in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

State Water System ID: 5400882.

Date distributed: 4.4-23

or, for continuing violations, for each day the more than \$25,000 for each day of violation one year, or by both the fine and imprisonments.	n, or by imprisonme	es, or be punished by ent in the county jail no	a fine of not ot to exceed

APPENDIX 2. CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION

Compliance Order Number: 03-24-22R-006

Name of Water System: Pleasant View West School

System Number: 5400882

Attach a copy of the public notice distributed to the water system's customers.

This form, when completed and sent to <u>dwpdist24@waterboards.ca.gov</u> for the Division of Drinking Water, Tulare District, 265 W. Bullard Avenue, Suite 101, Fresno, CA 93704, serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public notification for failure to comply with the Nitrate MCL was conducted on:	
Notification was made on(date).	
For the month, year ofMARCH_, 2023	
To summarize report delivery used and good-faith efforts taken, please check all items below the apply and fill-in where appropriate:	nat
For Community and non-transient non-community public water systems	
☐ The notice was distributed by mail or direct delivery to each customer on:	
One or more of the following methods were used to reach persons not likely to be reached by a mailing or direct delivery or persons served by a transient public water system (renters, nursing home patients, prison inmates, etc.): Posted the notice at the following conspicuous locations served by the water system. (If needed, please attach a list of locations).	
Publication of the notice in a local newspaper or newsletter of general circulation (attack copy of the published notice, including name of newspaper and date published).	ı a
Posted the notice on the Internet at www. pleasant - view . 06g	
Other method used to notify customers.	
I hereby certify that the above information is factual.	
Certified by: Printed Name Keiny Stewart Title Die of operations Signature Local Stars Date 4-4-2023	

Disclosure: Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation