

APPENDIX 1. NOTIFICATION TEMPLATE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Por favor hable con alguien que lo pueda traducir.

DRINKING WATER WARNING

Pleasant View West School water has high levels of nitrate
**DO NOT GIVE THE WATER TO INFANTS UNDER 6 MONTHS OLD
OR PREGNANT WOMEN OR USE IT TO MAKE INFANT FORMULA**

Water sample results received 9-12-22 [insert date] showed nitrate levels of 10.7 (mg/L) [insert level and units]. This is above the nitrate standard, or maximum contaminant level (MCL), of 10 milligrams per liter. Nitrate in drinking water is a serious health concern for infants less than six months old.

Use this paragraph when the levels are below the MCL.

Water sample results received _____ [insert date] showed nitrate levels of _____ [insert level and units]. This is below the nitrate standard, or maximum contaminant level (MCL), of 10 milligrams per liter. *Although the nitrate levels during the most recent monitoring period showed results below the MCL, nitrate levels in the water tend to fluctuate and it is possible that the nitrate level may increase at any time between sampling events. Public notification will continue until the nitrate problem is resolved.*

What should I do?

- **DO NOT GIVE THE WATER TO INFANTS.** *Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. Symptoms in infants can develop rapidly, with health deteriorating over a period of days. If symptoms occur, seek medical attention immediately.*
- **PREGNANT WOMEN SHOULD NOT CONSUME THE WATER.** *High nitrate levels may also affect the oxygen-carrying ability of the blood of pregnant women.*
- Water, juice, and formula for children under six months of age should not be prepared with tap water. Bottled water or other water low in nitrates should be used for infants until further notice.
- **DO NOT BOIL THE WATER.** Boiling, freezing, filtering, or letting water stand does not reduce the nitrate level. Excessive boiling can make the nitrates more concentrated, because nitrates remain behind when the water evaporates.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Nitrate in drinking water can come from natural, industrial, or agricultural sources (including septic systems, storm water run-off, and fertilizers). Levels of nitrate in drinking water can vary throughout the year. We will let you know if the amount of nitrate is again below the limit.

[Describe corrective action] DeVALLE LABORATORY will be conducting
QUARTERLY SAMPLES FOR NITRATES

We anticipate resolving the problem within [estimated time frame]

For more information, please contact:

[PN Contact Name] MARK ODSATHER
[Phone Number] or (559) 784-6769
[Mailing Address] 14004 ROAD 184, PORTERVILLE, CA. 93257

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- *SCHOOLS: Must notify school employees, students, and parents (if the students are minors).*
- *RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.*
- *BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.*

This notice is being sent to you by Pleasant View West School in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

State Water System ID: 5400882.

Date distributed: 10/5/2022

APPENDIX 2. CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION

Compliance Order Number: 03-24-22R-006

Name of Water System: Pleasant View West School

System Number: 5400882

Attach a copy of the public notice distributed to the water system's customers.

This form, when completed and sent to dwpdist24@waterboards.ca.gov for the Division of Drinking Water, Tulare District, 265 W. Bullard Avenue, Suite 101, Fresno, CA 93704, serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public notification for failure to comply with the **Nitrate MCL** was conducted on:

Notification was made on 10-3-2022 (date).

For the month, year of OCTOBER, 2022.

To summarize report delivery used and good-faith efforts taken, please check all items below that apply and fill-in where appropriate:

For Community and non-transient non-community public water systems

The notice was distributed by mail or direct delivery to each customer on: _____

One or more of the following methods were used to reach persons not likely to be reached by a mailing or direct delivery or persons served by a transient public water system (renters, nursing home patients, prison inmates, etc.):

Posted the notice at the following conspicuous locations served by the water system. (If needed, please attach a list of locations). Office, Teachers Lounge

Publication of the notice in a local newspaper or newsletter of general circulation (attach a copy of the published notice, including name of newspaper and date published).

Posted the notice on the Internet at www. pleasant-view.org

Other method used to notify customers. _____

I hereby certify that the above information is factual.

Certified by: Printed Name Marc Ocasio Title Superintendent
Signature [Signature]
Date 10/5/2022

Disclosure: Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation

or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than \$25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment

APPENDIX 3. QUARTERLY PROGRESS REPORT

Water System: Pleasant View West School	Water System No: 5400882
Compliance Order No: 03-24-22R-006	Violation: Nitrate MCL
Calendar Quarter:	Date:

This form should be prepared and signed by Water System personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The quarterly progress report must be submitted by the 10th day of each subsequent quarter, to the Division of Drinking Water, Tulare District Office to the following email address: dwpdist24@waterboards.ca.gov titled appropriately.

Summary of Compliance Plan:

DELLAVILLE Doing Quarterly TESTING on Well FOR NITRATES
 Begins OCTOBER 1, 2022

CULLIGAN WATER Be delivering BOTTLE WATER

Tasks completed in the reporting quarter:

Dellaville Laboratory Took Samples for Nitrates on Well 02
 ON 9.11.22

Tasks remaining to complete:

QUARTERLY SAMPLES

Anticipated compliance date:

8-10-2025


 Printed Name


 Signature


 Title

10/5/2022
 Date

APPENDIX 4. NOTIFICATION OF RECEIPT

Compliance Order Number: 03-24-22R-006

Name of Water System: Pleasant View West School

System Number: 5400882

Certification

I certify that I am an authorized representative of the Pleasant View West School and that Compliance Order No. **03-24-22R-006** was received on 8.30.2022. Further I certify that the Order has been reviewed by the appropriate management staff of the Pleasant View West School and it is clearly understood that Compliance Order No. **03-24-22R-006** contains legally enforceable directives with specific due dates.



Signature of Water System Representative



Date

**THIS FORM MUST BE COMPLETED AND RETURNED TO THE STATE WATER BOARD,
DIVISION OF DRINKING WATER, NO LATER THAN September 9, 2022.**

Disclosure: Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than \$25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment.